

01/2008:20920

Wet the inside of the filter holder fitted with the membrane filter with several millilitres of *particle-free water R*. Transfer to the filtration funnel the total volume of a solution pool or of a single unit, and apply vacuum. If needed, add stepwise a portion of the solution until the entire volume is filtered. After the last addition of solution, begin rinsing the inner walls of the filter holder by using a jet of *particle-free water R*. Maintain the vacuum until the surface of the membrane filter is free from liquid. Place the filter in a Petri dish and allow the filter to air-dry with the cover slightly ajar. After the filter has been dried, place the Petri dish on the stage of the microscope, scan the entire membrane filter under the reflected light from the illuminating device, and count the number of particles that are equal to or greater than 10 µm and the number of particles that are equal to or greater than 25 µm. Alternatively, partial filter count and determination of the total filter count by calculation is allowed. Calculate the mean number of particles for the preparation to be examined.

The particle sizing process with the use of the circular diameter graticule is carried out by transforming mentally the image of each particle into a circle and then comparing it to the 10 µm and 25 µm graticule reference circles. Thereby the particles are not moved from their initial locations within the graticule field of view and are not superimposed on the reference circles for comparison. The inner diameter of the transparent graticule reference circles is used to size white and transparent particles, while dark particles are sized by using the outer diameter of the black opaque graticule reference circles.

In performing the microscopic particle count test do not attempt to size or enumerate amorphous, semi-liquid, or otherwise morphologically indistinct materials that have the appearance of a stain or discoloration on the membrane filter. These materials show little or no surface relief and present a gelatinous or film-like appearance. In such cases the interpretation of enumeration may be aided by testing a sample of the solution by the light obscuration particle count test.

#### Evaluation

For preparations supplied in containers with a nominal volume of more than 100 ml, apply the criteria of test 2.A.

For preparations supplied in containers with a nominal volume of less than 100 ml, apply the criteria of test 2.B.

For preparations supplied in containers with a nominal volume of 100 ml, apply the criteria of test 2.B.

*Test 2.A – Solutions for infusion or solutions for injection supplied in containers with a nominal content of more than 100 ml*

The preparation complies with the test if the average number of particles present in the units tested does not exceed 12 per millilitre equal to or greater than 10 µm and does not exceed 2 per millilitre equal to or greater than 25 µm.

*Test 2.B – Solutions for infusion or solutions for injection supplied in containers with a nominal content of less than 100 ml*

The preparation complies with the test if the average number of particles present in the units tested does not exceed 3000 per container equal to or greater than 10 µm and does not exceed 300 per container equal to or greater than 25 µm.

## 2.9.20. PARTICULATE CONTAMINATION: VISIBLE PARTICLES

Particulate contamination of injections and infusions consists of extraneous, mobile undissolved particles, other than gas bubbles, unintentionally present in the solutions. The test is intended to provide a simple procedure for the visual assessment of the quality of parenteral solutions as regards visible particles. Other validated methods may be used.

#### APPARATUS

The apparatus (see Figure 2.9.20.-1) consists of a viewing station comprising:

- a matt black panel of appropriate size held in a vertical position,
- a non-glare white panel of appropriate size held in a vertical position next to the black panel,
- an adjustable lampholder fitted with a suitable, shaded, white-light source and with a suitable light diffuser (a viewing illuminator containing two 13 W fluorescent tubes, each 525 mm in length, is suitable). The intensity of illumination at the viewing point is maintained between 2000 lux and 3750 lux, although higher values are preferable for coloured glass and plastic containers.




Figure 2.9.20.-1. – Apparatus for visible particles

#### METHOD

Remove any adherent labels from the container and wash and dry the outside. Gently swirl or invert the container, ensuring that air bubbles are not introduced, and observe for about 5 s in front of the white panel. Repeat the procedure in front of the black panel. Record the presence of any particles.

01/2008:20922

## 2.9.22. SOFTENING TIME DETERMINATION OF LIPOPHILIC SUPPOSITORIES

The test is intended to determine, under defined conditions, the time which elapses until a suppository maintained in water softens to the extent that it no longer offers resistance when a defined weight is applied.

#### APPARATUS A

The apparatus (see Figure 2.9.22.-1) consists of a glass tube 15.5 mm in internal diameter with a flat bottom and a length of about 140 mm. The tube is closed by a removable plastic cover having an opening 5.2 mm in diameter. The apparatus comprises a rod 5.0 mm in diameter which becomes wider